

水質專區

水處供水系統內水質(移動年平均值)

資料來源：臺北自來水事業處水質科 時間：112年7月至113年6月

※註：ND表示低於偵測極限

項次	檢驗項目(單位)	水質標準限值	方法偵測極限	地點																										
				(0462) 德安公園	(0157) 黎孝公園	(0110) 民生加壓站	(0349) 富生公園	(2471) 民族東路	(2469a) 八德公園	(0507) 保福路	(0515) 中和員山路	(0528) 公館加壓站	(2506) 永和區	(0657) 三重同安東街	(0658) 三重頂崁街	(0797) 新店安康路	(0713) 光明路	(0722) 羅斯福路六段	(1087) 木新路	(0988) 中山北路一段	(0260) 三清宮	(1310a) 研究院路	(1346) 興南宮	(1480) 內湖大湖公園	(1501) 承德路七段	(1606) 陽明山格致路	(1621) 士林至善路	(0933d) 龍塘綠地	(1452) 汐止芳園街	
1	水溫(°C)	-	--	23.8	23.7	23.0	22.9	24.8	24.3	23.2	23.4	22.6	22.5	25.9	24.3	24.9	22.7	23.5	23.8	22.9	23.1	22.6	24.1	23.7	23.5	22.1	23.4	24.8	23.1	
2	濁度(NTU)	2	--	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.20	0.10	0.10	0.10	0.10	0.10	0.15	0.10	0.10	0.10	0.10	0.10	0.10	0.10	
3	色度(UNIT)	5	--	1	2	1	2	1	2	2	1	2	2	2	2	2	2	1	2	1	2	1	1	1	2	1	1	1	1	
4	總餘度(mg/L)	-	--	24.1	24.6	21.2	22.2	20.9	21.7	24.1	25.0	23.4	23.4	23.7	24.9	22.9	22.9	24.1	23.6	24.3	22.2	25.6	25.8	24.0	24.8	38.9	36.2	24.4	25.5	
5	pH值	6.0-8.5	--	7.4	7.3	7.2	7.4	7.2	7.4	7.3	7.3	7.2	7.3	7.3	7.4	7.3	7.3	7.4	7.3	7.5	7.4	7.4	7.3	7.3	7.4	7.4	7.5	7.3	7.3	
6	自由有效餘氯(mg/L)	0.2-1.0	0.0125	0.48	0.48	0.47	0.51	0.52	0.48	0.53	0.46	0.51	0.54	0.51	0.49	0.48	0.54	0.49	0.45	0.49	0.47	0.45	0.40	0.42	0.47	0.54	0.52	0.50	0.45	
7	氨氮(mg/L)	0.1	0.0125	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
8	亞硝酸鹽氮(mg/L)	0.1	0.00027	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
9	總溶解固體量(mg/L)	500	--	67	66	63	64	62	65	59	61	61	58	59	61	59	59	66	65	63	66	65	61	63	62	129	90	62	62	
10	總硬度(mg/L)	300	0.875	30.9	30.4	30.2	30.0	28.4	29.1	28.5	29.9	29.7	28.9	28.5	28.8	29.1	29.1	31.9	31.9	31.1	30.4	35.5	31.9	31.6	31.5	66.9	39.3	29.9	30.1	
11	鈣(mg/L)	-	0.377	8.0	7.4	7.0	6.5	7.2	7.0	8.4	7.8	7.4	7.9	7.7	7.6	8.2	7.5	7.5	8.1	7.8	6.9	7.6	7.5	8.2	7.7	18.9	10.4	7.6	8.5	
12	鎂(mg/L)	-	--	2.1	2.3	2.2	2.2	1.7	2.1	1.9	2.6	2.5	2.2	2.3	2.4	2.1	2.6	2.6	2.2	2.3	2.2	2.7	2.9	2.0	2.4	4.5	3.6	2.5	2.2	
13	總有機碳(mg/L)	---	0.058	0.2	0.2	0.2	0.4	0.2	0.2	0.3	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.3	0.2	0.2	0.2	0.4	0.2	<0.1	0.5	0.2	0.2	
14	總三鹵甲烷(mg/L)	0.08	--	0.00969	0.0101	0.00789	0.00753	0.00857	0.00897	0.00789	0.00870	0.00641	0.00791	0.00732	0.00776	0.00860	0.00765	0.00737	0.00820	0.00762	0.00912	0.00904	0.0116	0.00932	0.00901	0.00043	0.0178	0.00805	0.0105	
15	鐵(mg/L)	0.3	0.00191	0.002	ND	0.008	0.003	ND	0.002	ND	0.004	ND	ND	0.002	0.004	0.004	ND	0.002	ND	0.004	ND	ND	0.004	ND	0.002	0.003	ND	ND	0.006	
16	錳(mg/L)	0.05	0.00085	ND	ND	0.003	ND	0.002	0.001	ND	0.001	0.007	0.001	0.001	0.001	0.001	0.001	ND	ND	0.001	0.001	ND	0.002	0.001	0.002	ND	ND	0.002	ND	
17	鉛(mg/L)	0.01	0.00112	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
18	鋁(mg/L)	0.2	0.00218	0.074	0.061	0.061	0.073	0.057	0.066	0.044	0.060	0.075	0.045	0.061	0.058	0.066	0.040	0.065	0.052	0.063	0.065	0.043	0.068	0.063	0.065	0.024	0.059	0.057	0.058	
19	銀(mg/L)	0.05	0.00084	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
20	銅(mg/L)	1.0	0.00112	ND	ND	ND	ND	0.002	ND	0.002	ND	ND	ND	ND	0.002	ND	ND	ND	ND	ND	ND	0.002	ND	ND	ND	ND	ND	0.002	ND	
21	鋅(mg/L)	5.0	0.00085	0.002	0.002	ND	0.001	0.004	0.002	0.004	0.002	0.001	0.002	0.004	0.016	0.004	0.003	ND	0.002	0.001	ND	0.002	0.002	0.001	0.001	0.001	0.001	ND	0.003	0.004
22	鎘(mg/L)	0.005	0.00082	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
23	鎳(mg/L)	0.02	0.00071	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
24	總菌落數(CFU/mL)	100	--	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	1	<1	<1	<1

