



33	銅	mg/L	1.0	<b>0.00112</b>	ND	ND	ND	ND	ND	ND	ND	ND
34	鋅	mg/L	5.0	<b>0.00085</b>	ND	ND	0.002	ND	0.001	ND	0.001	ND
35	硒	mg/L	0.01	<b>0.00157</b>	ND	ND	ND	ND	ND	ND	ND	ND
36	銻	mg/L	0.01	<b>0.00079</b>	ND	ND	ND	ND	ND	ND	ND	ND
37	銀	mg/L	2.0	<b>0.00076</b>	0.007	0.008	0.008	0.010	0.009	0.002	0.005	0.008
38	鎳	mg/L	0.02	<b>0.00071</b>	ND	ND	ND	ND	0.001	ND	ND	ND
39	鹵乙酸類	mg/L	0.060	--	0.00558	0.00649	0.00537	0.0114	ND	ND	0.0101	0.00655
40	氯乙烯	mg/L	0.0003	<b>0.000088</b>	ND	ND	ND	ND	ND	ND	ND	ND
41	1,1-二氯乙烯	mg/L	0.007	<b>0.000028</b>	ND	ND	ND	ND	ND	ND	ND	ND
42	1,1,1-三氯乙烯	mg/L	0.20	<b>0.000013</b>	ND	ND	ND	ND	ND	ND	ND	ND
43	四氯化碳	mg/L	0.005	<b>0.000012</b>	ND	ND	ND	ND	ND	ND	ND	ND
44	苯	mg/L	0.005	<b>0.000048</b>	ND	ND	ND	ND	ND	ND	ND	ND
45	1,2-二氯乙烯	mg/L	0.005	<b>0.000016</b>	ND	ND	ND	ND	ND	ND	ND	ND
46	三氯乙烯	mg/L	0.005	<b>0.000011</b>	ND	ND	ND	ND	ND	ND	ND	ND
47	1,4-二氯苯	mg/L	0.075	<b>0.000016</b>	ND	ND	ND	ND	ND	ND	ND	ND
48	二氯甲烷	mg/L	0.02	<b>0.000046</b>	0.00012	ND	ND	ND	ND	ND	ND	ND
49	鄰-二氯苯	mg/L	0.6	<b>0.000018</b>	ND	ND	ND	ND	ND	ND	ND	ND
50	甲苯	mg/L	0.7	<b>0.000054</b>	0.00118	0.00136	0.00140	ND	0.00144	0.00177	ND	0.00234
51	二甲苯	mg/L	0.5	--	ND	ND	ND	ND	ND	ND	ND	ND
52	順-1,2-二氯乙烯	mg/L	0.07	<b>0.000014</b>	ND	ND	ND	ND	ND	ND	ND	ND
53	反-1,2-二氯乙烯	mg/L	0.1	<b>0.000010</b>	ND	ND	ND	ND	ND	ND	ND	ND
54	四氯乙烯	mg/L	0.005	<b>0.000011</b>	ND	ND	ND	ND	ND	ND	ND	ND
55	酚類	mg/L	0.001	<b>0.00046</b>	ND	ND	ND	ND	ND	ND	ND	ND
56	氰鹽	mg/L	0.05	<b>0.00048</b>	ND	ND	ND	ND	ND	ND	ND	ND
57	溴酸鹽	mg/L	0.01	<b>0.00090</b>	ND	ND	ND	ND	ND	ND	ND	ND
58	亞氯酸鹽	mg/L	0.7	<b>0.0010</b>	ND	ND	ND	ND	ND	ND	ND	ND
59	安殺番	mg/L	0.003	--	ND	ND	ND	ND	ND	ND	ND	ND
60	靈丹	mg/L	0.0002	<b>0.0000046</b>	ND	ND	ND	ND	ND	ND	ND	ND
61	丁基拉草	mg/L	0.02	<b>0.000057</b>	ND	ND	ND	ND	ND	ND	ND	ND
62	2,4-地	mg/L	0.07	<b>0.000039</b>	ND	ND	ND	ND	ND	ND	ND	ND
63	巴拉刈	mg/L	0.01	<b>0.00128</b>	ND	ND	ND	ND	ND	ND	ND	ND
64	納乃得	mg/L	0.01	<b>0.00012</b>	ND	ND	ND	ND	ND	ND	ND	ND
65	加保扶	mg/L	0.02	<b>0.00017</b>	ND	ND	ND	ND	ND	ND	ND	ND
66	滅必蟲	mg/L	0.02	<b>0.00020</b>	ND	ND	ND	ND	ND	ND	ND	ND
67	達馬松	mg/L	0.02	<b>0.000032</b>	ND	ND	ND	ND	ND	ND	ND	ND
68	大利松	mg/L	0.005	<b>0.000041</b>	ND	ND	ND	ND	ND	ND	ND	ND
69	巴拉松	mg/L	0.02	<b>0.000067</b>	ND	ND	ND	ND	ND	ND	ND	ND
70	一品松	mg/L	0.005	<b>0.000098</b>	ND	ND	ND	ND	ND	ND	ND	ND
71	亞素靈	mg/L	0.003	<b>0.000059</b>	ND	ND	ND	ND	ND	ND	ND	ND
水質合格否(Y/N)					Y	Y	Y	Y	Y	Y	Y	Y